



## Refilling Instructions

Only for use with the CommanderEDGE LFX Fire Extinguisher Range.

**Wear eye protection and gloves when handling this product.**

1. Discharge the fire extinguisher so it is no longer pressurised.
2. Remove the valve from the head of the extinguisher
3. Empty the contents of the fire extinguisher into a suitable container and dispose of according to local regulations.
4. After removing the extinguishing agent thoroughly wash the tank with water to remove any residue of old extinguishing agent.
5. Slowly add the entire contents of this refill pack to empty fire extinguisher.
6. Reinsert the valve into the fire extinguisher and tighten to the required torque.
7. Pressurise the fire extinguisher to the required bar (Green section on the gauge).
8. In the upright position with the valve upwards, insert the extinguisher into a water tank to check for leaks.
9. Reinsert the locking pin and a new pull tight seal.



029 2086 8333



[sales@checkfire.co.uk](mailto:sales@checkfire.co.uk)



[www.CheckFire.co.uk](http://www.CheckFire.co.uk)



[Click here to sign up to our newsletter](#)

**CheckFire.**  
checkfire.co.uk